

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 4485-0941:106 Page 1 of 1

CATEGORY: Opening Protection (Firestopping)

LISTEE: Minnesota Mining & Mfg. (3M), 3M Ctr, Bldg. 225-1S-02, St. Paul MN 55144
Contact: *Brandon Cordts (651) 733-5580 Fax (651) 737-2263

DESIGN: Models INTERAM FIRE DAM FD150 caulk. Refer to listee's data sheet for detailed product description and operational considerations. Additional information may also be found in the UL Fire Resistance Directory XR201 and X203; and UL Building Materials Directory (Systems 161, 170, 171 and 172).

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation, hourly rating and UL label.

APPROVAL: Listed as 2-hour to 3-hour fire-rated firestopping material when constructed in accordance with UL Directories.

*Rev. 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

AUGUST 20, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager